

ECLIPSE RUSSELLVILLE - RV Park and Campground Guidelines

The following are Recreational Vehicle (RV) Park and Campground Standards set forth in NFPA 1194, NFPA 10, NFPA 1192

1. Means of Access

A site plan shall be available for emergency responders showing means of access for response vehicles.

2. Turn-around

Turn-arounds shall be provided for all dead-end roads greater than 100 feet in length.

3. Road Width

Minimum widths of RV park and campground roads shall be 10 ft per traffic lane and 8 feet per parallel parking lane.

4. RV /Camper Unit and Site Spacing

Each camping unit site shall be a minimum width of 10 feet for RV/Camping unit.

Each camping unit site shall be separated by a minimum of 20 feet.

5. Fire Extinguishers

Multi-purpose dry chemical type

2-A:20-B:C minimum rating

Mounted and located in a conspicuous, accessible space

Maximum travel distance 75 ft

6. Propane Containers

Maximum container capacities shall not exceed the RV manufacturer's requirements.

Cylinders shall be constructed and marked in accordance with US DOT.

Propane cylinders shall be mounted and secured in a place that will not become dislodged and in accordance with the RV manufacturer's requirements and NFPA 1192.

7. Campfire Locations

Approved designated outdoor campfire locations, if provided, shall be in areas that do not constitute fire hazards to vegetation, undergrowth, trees, RVs, camping units, and structures.

8. Evacuation Plan

A written evacuation plan shall be provided.